



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

January 25, 2008

WIESER CONCRETE PRODUCTS, INC.
MARK WIESER
2815 RILEY ROAD
PORTAGE WI 53901

FERNO-WASHINGTON, INC.
GORDON A. SHIELDS
70 WEIL WAY
WILMINGTON OH 45177

Re: Description: SEWAGE TREATMENT APPARATUS (also see SEWAGE TANKS)
Manufacturer: FERNO-WASHINGTON, INC.
Product Name: BIO-MICROBICS MICRO FAST OR HIGH STRENGTH FAST 3.0
Model Number(s): W4500/4500 BIO (Septic/Bio-Microbics or Bio-Microbics/Pump)
Product File No: 20080036

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of June 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- This tank may only be installed in conjunction with the Bio-Microbics Inc., sewage treatment apparatus.

This approval supersedes the approval issued on 6/6/2003 under product file number 20030175.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030175.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov